MONTGOMERY COLLEGE - OFFICE OF PROCUREMENT

REQUEST FOR BID TITLE: Eaton Powerware Replacement Batteries

BID NUMBER: 519-018

BID OPENING DATE AND TIME: February 28, 2019 @ 3:00 p.m.



ADDENDUM #1

Issued: February 18, 2019

ADDENDUM FOR THE PURPOSE OF:

- Change the opening date of the RFB from 3:00 PM February 21, 2019 to 3:00 PM February 28, 2019
- Replace Section 2- Background and Specifications of the RFB with revised Section 2 Background and Specifications.
- Replace Section 3 Price Proposal of the RFB with revised Section 3 Price Proposal.

All other specifications, terms and conditions remain unchanged.

Patrick Johnson
Director of Procurement

Please **sign** below to acknowledge receipt of this Addendum and return with the proposal. Failure to return this Acknowledgement of Addendum may deem a proposal nonresponsive.

NOTE: ACKNOWLEDGEMENT OF RECEIPT OF BID ADDENDA WILL NOT BE ACCEPTED BY FACSIMILE OR E-MAIL.

Company Name

Authorized Signature

Date

Printed/Typed Signature

MONTGOMERY COLLEGE - OFFICE OF PROCUREMENT

REQUEST FOR BID TITLE: Eaton Powerware Replacement Batteries

BID NUMBER: 519-018

BID OPENING DATE AND TIME: February 28, 2019 @ 3:00 p.m.

SECTION 2 - REVISED BACKGROUND AND SPECIFICATIONS

2.1 Specifications

Bidder must provide pricing including delivery for all items as listed on the price proposal to be considered for award. All item(s) **must be new** and not remanufactured, reconditioned, and/or refurbished. All item(s) are not brand specific and may be substituted. Bidder must list the manufacturer and part number that is being offered on the price proposal page and provide detailed specification sheet. The College reserves the right to reject an offered alternative.

MONTGOMERY COLLEGE - OFFICE OF PROCUREMENT

REQUEST FOR BID TITLE: Eaton Powerware Replacement Batteries

BID NUMBER: 519-018

BID OPENING DATE AND TIME: February 28, 2019 @ 3:00 p.m.

SECTION 3 – REVISED PRICE PROPOSAL

Item No.	Description	UM	QTY	Unit Price	Total Price
1	Complete Battery Replacement and required voltage adjustment to be performed by an Eaton Authorized service Technician for the following Eaton Powerware UPS units, each unit to be provide with 80 of the following batteries, #PWHR12390W4FR 1. Eaton #9390-100-160, serial# EY442CCBA02 2. Eaton #9390-100-160, serial# EY441CBA09 3. Eaton #9390-100-160, serial# EG053CBC07 Must include • Dock to dock only delivery • Installation, Removal and EPA Disposal of old batteries	EACH	3	\$	\$
	3 year labor and batteries Warranty				
	List Manufacture of battery replacement				
	List the Part number of battery replacement	FACIL	1 2		<u> </u>
2	Corrective Labor Coverage for line item #1 extended to 3 years to commence at battery installation	EACH	3	\$	\$
3	Complete Battery Replacement and required voltage adjustment to be performed by an Eaton Authorized service Technician for the following Eaton Powerware UPS unit. The Ups needs to be provided with 160 #PWHR12500W4FRbatteries 1. Eaton #9395-550-550-CC, serial# EF444BAA06 Must include Dock to dock only delivery Installation, Removal and EPA Disposal of old batteries 3 year labor and batteries Warranty	EACH	1	\$	\$
	List Manufacture of battery replacement				
	List the Part number of battery replacement			,	
4	Corrective Labor Coverage for line item #3 extended to 3 years to commence at battery installation	EACH	1	\$	\$
			GRA	ND TOTAL	\$

Earliest Delivery Date After Receipt of Order (ARO): If applicable, the stated delivery date <u>may</u> be considered in evaluation of the award. Indicate number of business days for delivery ARO:
Bidders must submit prices and all additional information requested for all line items, including delivery, to be considered for award: failure to do so will deem an offer non-responsive.
Note to Bidder: Submitted price must be inclusive of all costs associated with all requirements listed herein. Montgomery College is tax exempt, certification provided upon request
By signing below, your firm agrees to provide said goods and/or services as specified and that those goods and/or services shall be provided or performed in accordance with the bid specifications, stipulations and terms and conditions specified and that your firm has read and agrees to the College terms, conditions,

Company Name

Authorized Name (printed/typed)

Title

Authorized Signature and Date

stipulations, and specifications and any College approved or authorized exceptions and that your firm will adhere to said terms and conditions in any contract resulting.