



OFFICE OF PROCUREMENT

TIME AND MATERIALS ON-CALL PAVING SERVICES
RFP NO.: 619-008
RFP CLOSING DATE AND TIME: APRIL 29, 2019 @ 3:00 PM

ADDENDUM #2
Issued on April 22, 2019

This Addendum is for the purposes of providing answers to the RFIs and making changes to the RFP requirements as follows:

Item 2-1 Extend the RFP closing date and time from April 24, 2019 at 3 PM to April 29, 2019 at 3 PM.

Item 2-2 Question: Will the College contract for the Pavement Marking?

Answer: Based on the project conditions, College may ask the prospective Contractor to provide Pavement Marking by hiring a sub-contractor.

Item 2-3 Question: Please confirm that per Pre-Proposal Meeting, Section 002213-1, SUPPLEMENTARY INSTRUCTIONS TO CONTRACTORS, PART 2 – PREVAILING WAGES, that no state or federal money will be used, so no wage rates apply.

Answer: The College does not anticipate any state or federal funds to be used.

Item 2-4 Question: Section 3.8 in the General Conditions, Reference Documents, will the Contractor be required to provide a surveyor for stakeout and as builds?

Answer: The stakeout and as-built will be provided by College's Consultant.

Item 2-5 Question: Is all HMA mixes Level 1, when not labeled as such?

Answer: Delete references to "Level 1" from #27 to #30.

Item 2-6 Question: What Performance Grade is the liquid asphalt for items 27 - 42?

Answer: SuperPave PG64-22 is to be used.

Item 2-7 Question: Per 32 12 16, 2.2.A, Asphalt binder is PG64-22 however the bid items specify PG70-22. PG70-22 is very hard to obtain, most plants will not price it, will the College accept all PG64-22?

Answer: Use SuperPave PG64-22 where PG70-22 is referenced.

OFFICE OF PROCUREMENT

TIME AND MATERIALS ON-CALL PAVING SERVICES
RFP NO.: 619-008
RFP CLOSING DATE AND TIME: APRIL 29, 2019 @ 3:00 PM

ADDENDUM #2
Issued on April 22, 2019

Item 2-8 Question: Per 32 12 16, 2.3.B, will herbicides be required? If so what requirements for the applicator will be needed?

Answer: No application of herbicides will be required.

Index of Attachments to Addendum

Specification Sections or Portions Reissued in Entirety:

NONE

Drawings Reissued in Entirety:

NONE

Sketches:

NONE

Items Issued for Informational Purposes:

NONE



Patrick Johnson, MBA
Director of Procurement

Please **sign** below to acknowledge receipt of this Addendum and return with the **Technical Proposal submission**. Failure to return this Acknowledgement of Addendum may deem a proposal nonresponsive.

NOTE: ACKNOWLEDGEMENT OF RECEIPT OF RFP ADDENDA WILL NOT BE ACCEPTED BY FACSIMILE OR E-MAIL.

Company Name

Authorized Signature

Date

Printed/Typed Signature