

**OFFICE OF PROCUREMENT  
SIDEWALK REPLACEMENT, ROCKVILLE CAMPUS  
RFP NO.: 622-010  
RFP CLOSING DATE AND TIME: MAY 23, 2022 @ 2:00 PM**

**ADDENDUM #2  
ISSUED: MAY 20, 2022**

---

**THE PURPOSE OF ADDENDUM IS TO PROVIDE THE ANSWER TO THE FOLLOWING REQUEST FOR CLARIFICATION.**

Item 2-1 Question: Question regarding IT Alternate No.3 IT Conduit. Drawing T001 indicates that the base bid must include IT conduit in the cast in place and the Alternate #3 include IT conduit on direct burials. Could you please confirm or clarify?

Answer: Base bid shall include pricing for placing IT conduit in concrete duct banks as per the drawings and specifications. Alternate #3 pricing shall deduct the cost of placing the IT conduits in concrete duct banks and add the cost of direct burial.

All other specifications, terms and conditions remain unchanged.

**Sections or Portions Reissued in Entirety**

NONE

**Drawings**

NONE

**Sketches**

NONE

**Items Issued for Informational Purposes**

NONE



---

**Patrick Johnson, MBA**  
Director of Procurement

Please **sign** below to acknowledge receipt of this Addendum and return with the **Technical Proposal submission**. Failure to return this Acknowledgement of Addendum may deem a proposal nonresponsive.

**NOTE: ACKNOWLEDGEMENT OF RECEIPT OF RFP ADDENDA WILL NOT BE ACCEPTED BY FACSIMILE OR E-MAIL.**

---

Company Name

---

Authorized Signature

---

Date

---

Printed/Typed Signature