

**MONTGOMERY COLLEGE - OFFICE OF PROCUREMENT
UNDERGROUND CHILLED AND HEATING WATER PIPING REPLACEMENT – PHASE 1
ROCKVILLE CAMPUS
RFP NO.: E621-006
RFP CLOSING DATE AND TIME: APRIL 9, 2021 @ 2:00 PM**

**ADDENDUM #2
Issued: April 1, 2021**

THIS ADDENDUM IS TO PROVIDE ANSWERS TO THE FOLLOWING QUESTIONS:

NOTE: Similar requests for information that were received from different Contractors have been grouped under a single addendum item where appropriate, with a single comprehensive answer provided.

The following items offer clarifications that do change the requirements of the RFP documents.

Item 2-1 Question: The pipe replacement project at Montgomery College-Rockville Campus. The site drawings indicate 8" chilled water mains and 6" heating mains with smaller lines to the buildings. CS-101 shows the same for the new pipe. However, M1.01 and M1.02 are showing 10" chilled and 8" heating. Please confirm the sizes of the new piping to be installed, as this will have a direct impact on pricing and fabrication from the Perma-Pipe distributor.

Answer: Contractor shall refer to M1.01/M1.02 & M1.04/M1.05 for chilled and heating water pipe sizes.

Specification Sections or Portions Reissued in Entirety

None

Drawings Reissued in Entirety

None

Sketches

None

Items Issued for Informational Purposes

None



Patrick Johnson, MBA
Director of Procurement

**MONTGOMERY COLLEGE - OFFICE OF PROCUREMENT
UNDERGROUND CHILLED AND HEATING WATER PIPING REPLACEMENT – PHASE 1
ROCKVILLE CAMPUS
RFP NO.: E621-006
RFP CLOSING DATE AND TIME: APRIL 9, 2021 @ 2:00 PM**

**ADDENDUM #2
Issued: April 1, 2021**

Please **sign** below to acknowledge receipt of this Addendum and return with the **Technical Proposal submission**. Failure to return this Acknowledgement of Addendum may deem a proposal nonresponsive.

NOTE: ACKNOWLEDGEMENT OF RECEIPT OF RFP ADDENDA WILL NOT BE ACCEPTED BY FACSIMILE.

Company Name

Authorized Signature

Date

Printed/Typed Signature